

P167-10456

**ADDENDUM NUMBER:** Addendum - One

**PROJECT TITLE:** Milwaukee County Parks Department  
**Wilson Park Recreation Center**  
Toilet Room Renovations  
Site Number: 649  
Building Number: 3860  
4001 South 20<sup>th</sup> Street  
Milwaukee, WI. 53221

**PROJECT NUMBER:** P167-10456

**DATE OF ADDENDUM:** March 02, 2011

This Addendum to the Contract Documents is issued to modify, explain or correct the original Documents, Dated February 08, 2011, and is hereby made part of the Contract Documents. Acknowledge receipt of this addendum in the space provided on the Bid Form, or bid may be rejected.

#### SPECIFICATIONS

Section 22 42 00 – Commercial Plumbing Fixtures; Part 2 – Products; 2.01 Plumbing Fixtures;  
B. Water Closets:

Revise: WC-1 Water Closet

- Flush Valve: *Sloan Royal #111-1.6 low consumption (1.6 gpf).*

Revise: WC-2 Water Closet

- Flush Valve: *Sloan Royal #111-1.6 low consumption (1.6 gpf).*

C. Urinals:

Revise: UR-1 Urinal

- Flush Valve: *Sloan Royal Model – Flushometer #186-1.0 low consumption low consumption (1.0 gpf).*

END OF SECTION